


Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Available Lug Kit	Terminal Hole Size (Inches)
KDRG31PV	250	242	250	44	161	60	SLK12	0.44
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Available Lug Kit	Terminal Hole Size (Inches)
KDRG47LV	250	242	242	108	394	65	SLK12	0.44



**TCI** (800) 824-8282 transcoll.com

TCI, LLC  
 Germantown, WI, USA  
 transcoll.com  
 800-824-8282


KDR/L Drive Reactor  
 KDR - Motor Amps ---  
 3PH, 50/60Hz, ---V Rated, 600V Max, -A Max  
 40C Amb Max, 155C Rise, RoHS  
 Manual #30895 LUG KIT #SLK---

UL LISTED  
 2ND EDITION, 10, 1995

DATE CODE A1 B1 C1

Notes:

1. KDR Lug Kits sold separately. Contact TCI.
2. UL file number: cULus Listed File E116124.
3. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
4. KDR IOM Manual Part Number 30895
5. Material(s) Shall be RoHS Compliant
6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.



THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°				W132N10611 (Rev 13 Feb 2024) Germantown, WI 53022 © 2024 TCI, LLC An Official Motors Group Company KDR G Frame, 690V Reactor Drawing 103100-1DG SCALE: 1/2 DRAWN: DSW DATE: 6/24/2024 DESIGNED: DSW CHECKED: [ ]	
NO	REVISION	DATE	BY	NO	DATE	BY	NO	DATE	BY