

- Notes:
- 1.) Mounting hole diameter is .64 inches.
 - 2.) The "A" mounting holes are mandatory the "B" holes are optional.
 - 3.) To insure proper cooling maintain 3 inch clearance on sides and front.
 - 4.) This is UL Type 1, Listed.


- Drawings:
- General Schematic: #29071
 - Customer Connection #25027-3
 - Interface/Display Module #28283-1
 - Current Transformer #26461
 - Pedestal Assy Drawing #29253

- Weights lbs (Kg):
- Filter/Enclosure 722 (327.5)
 - Pedestal 43.3 (19.6)

*NOTE
This unit is rated for 220A when applied with a 480V/600V autotransformer

WARNING: Filter must be securely anchored to the floor to avoid a tipping hazard!

Total heat loss 10,500 watts, 35,828 Btu/h.

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.	F	chg CCD 28461 to 25027-3	12/18/19	MJS	TOLERANCES (EXCEPT AS NOTED) DECIMAL	 W132 N10611 Grant Drive Germantown, WI 53022 Outline/Installation, Active Filter, w-Pedestal, 300 Amp DRN. BY RHW DATE 5/17/14 DWG. NO. 105764 SCALE N/A SIZE B SHT. 1 OF 1
	E	Add 600V rating note	12/14/18	MJS		
	D	Fix dwg list again	11/27/17	MJS	.XX ±.05	
	C	Fix drawing list	9/1/15	RHW	.XXX±.025	
	B	Add bottom wire entry	1/26/15	MJS	FRACTIONAL ± 1/32	
	A	Update Dwg List	11/24/14	RHW	ANGULAR ± 1/2°	
	NO	REVISION	DATE	BY		