



WARNING: Filter must be securely anchored to the floor to avoid a tipping hazard.

Drawings:
 General Schematic: #26463-04
 Customer Connection: #25027-3
 Interface/Display Module: #28283-1
 Current Transformer: #26461
 Pedestal Assy Drawing: #30847

Weights lbs (Kg):
 Filter/Enclosure: 254(115.2Kg)
 Pedestal: 64(29Kg)

Total Heat Loss:
 50A: 2676 watts, 9,131 Btu/hr
 100A: 3500 watts, 11,942 Btu/hr

For TCI Catalog #HGAF01D01A

Note:
 The 50A unit is rated for 39A when applied with a 480V/600V autotransformer
 The 100A unit is rated for 78A when applied with a 480V/600V autotransformer

- Notes:
- 1) Mounting hole Diameter is .64 inches
 - 2) The "A" mounting holes are mandatory. The "B" mounting holes are optional.
 - 3) to insure proper cooling maintain 6 inch clearance on sides and front.

				TOLERANCES (EXCEPT AS NOTED)	TCI W132 N10611 Grant Drive Germantown, WI 53022
				DECIMAL	
				.XX ± .03 .XXX ± .010	Outline, Installation, 50A/100A Active Filter, Type 1, Floor Mount
C	corrected pedestal weight HMI upgrade	8/26/20	MJS	FRACTIONAL ± 1/32	
B	added 600V rating notes	12/18/18	MJS	ANGULAR ± 1°	DRN. BY MJS
A	Added Pedestal Info	12/4/17	MJS		DATE: 11/16/17
NO	REVISION	DATE	BY		APRVD:
					SCALE: yes
					SIZE B
					107432
					SHT.1 OF 1