






575 Rated Voltage, 600 Max Voltage, Low Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Attached Lug Kit
KDRULG45L	300	289	292	98.8	374	67	SLK12



(Customer Connections) Markings On Coils For Reference Only.



**TCL** (800) 824-8282 transcoil.com

TCL, LLC  
Germantown, WI, USA.  
transcoil.com  
800-824-8282


KDRUL Drive Reactor  
KDR - Motor Amps ---  
3PH, 50/60Hz, ---V Rated, 600V Max, -A Max  
40C Amb Max, 155C Max, RoHS  
Manual #30895 LUG KIT #SLK

UL LISTED CE  
2nd ed. 10, 2010 © 2024 TCL, LLC

DATE CODE A1 B1 C1

Notes:

1. UL file number: cULus Listed File E116124.
2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
3. KDR IOM Manual Part Number 30895
4. Material(s) Shall be RoHS Compliant
5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.



THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
A	107533-4 to 107533-14	6/24/2024	DSW

TOLERANCES (EXCEPT AS NOTED)		SCALE	
DECIMAL	.XX ± .25 .XXX ± .10	1/2	DRWG
FRACTIONAL	± 1/32	1/2	DRWG
ANGULAR	± 1°	1/2	DRWG

W132N10611 (Rev. 11/16)  
 Germantown, WI 53022 © 2024 TCL, LLC  
 An Official Motors Company  
 KDRUL G Frame, Copper Bus  
 Reactor Drawing  
 DESIGNED BY: DSW DATE: 6/24/2024 107533-14DG  
 DRAWN BY: DSW DATE: 6/24/2024 107533-14DG  
 CHECKED BY: DSW DATE: 6/24/2024 107533-14DG  
 SCALE: 1/2 DRWG: SHEET 1 OF 1