



(Customer Connections)  
Markings On Coils  
For Reference Only.



575 Rated Voltage, 600 Max Voltage, High Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Attached Lug Kit
KDRULG45H	150	144	155	326	400	66	SLK11

**TCL** (800) 824-8282 transcoil.com

TCL, LLC  
Germantown, WI, USA.  
transcoil.com  
800-824-8282

KDRUL Drive Reactor  
KDR - Motor Amps -  
3PH, 50/60Hz, -V Rated, 600V Max, -A Max  
40C Amb Max, 155C Max, RoHS  
Manual #30895 LUG KIT #SLK-

UL LISTED CE  
200-0000-10, 10000

DATE CODE A1 B1 C1

Notes:

1. UL file number: cULus Listed File E116124.
2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
3. KDR IOM Manual Part Number 30895
4. Material(s) Shall be RoHS Compliant
5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.			
A	107533-4 to 107533-16	6/24/2024	DSW
NO	REVISION	DATE	BY

TOLERANCES (EXCEPT AS NOTED)	
DECIMAL	.XX ± .25 .XXX ± .10
FRACTIONAL	± 1/32
ANGULAR	± 1°

**TCL** W132N10611 (Rev 1) 15Feb  
Germantown, WI 53022  
© 2024 TCL, LLC

An Official Motors Company  
KDRUL G Frame, Copper Bus  
Reactor Drawing

DRN BY: DSW DATE: 6/24/2024 107533-19DG  
SCALE: 1/2 DRAWING: 1/2 SHEET: 1 OF 1