


(Customer Connections) Markings On Coils For Reference Only.



480 Rated Voltage, 600 Max Voltage, Output								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Available Lug Kit	Terminal Hole Size (Inches)
KDRL1P	350	414	420	26.4	275	85	SLK13	0.53
KDRL2P	400	477	480	23.1	267	95	SLK13	0.53
KDRL3P	450	515	600	19	338	100	SLK14	0.53
KDRL4P	500	590	600	18.7	338	100	SLK14	0.53

575 Rated Voltage, 600 Max Voltage, Output								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Terminal Hole Size (Inches)	Weight (LBS)	Available Lug Kit	Losses (W)
KDRL31P	400	382	420	26.5	0.53	85	SLK13	420
KDRL35P	450	412	420	26.4	0.53	85	SLK13	420
KDRL32P	500	472	480	23.7	0.53	95	SLK13	480

480 Rated Voltage, 600 Max Voltage, High Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Losses (W)	Weight (LBS)	Available Lug Kit	Terminal Hole Size (Inches)
KDRL1H	250	302	310	106	548	105	SLK13	0.56
KDRL2H	300	361	365	86	786	105	SLK13	0.56
KDRL3H	350	414	435	74	750	109	SLK13	0.53
KDRL4H	400	477	480	65	730	135	SLK13	0.56

TCI (800) 824-8282 transcoll.com

TCI, LLC
Greenfield, WI, USA.
transcoll.com
800-824-8282

KDRL Drive Reactor
KDR - Motor Amps -
3PH, 50/60Hz -V Rated, 600V Max, -A Max
40C Amp Max, 155C Rise, RoHS
Manual #30895 LUG KIT #SLK-

UL LISTED CE
2500 0001 09 0000

DATE CODE: A1 A2 B1 B2 C1 C2

- Notes:
1. KDR Lug Kits sold separately. Contact TCI.
 2. UL file number: cULus Listed File E116124.
 3. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 4. KDR IOM Manual Part Number 30895
 5. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 6. Material(s) Shall be RoHS Compliant
 7. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.								TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10		W132N10611 (Rev 11/16) Greenfield, WI 53012 © 2024 TCI, LLC An Official Motors Company KDR L Frame, Copper Bus Reactor Drawing DWN BY: DSW DATE: 3/23/18 107537-5DG SCALE: 1/3.2 DRAWN BY: CJC SHEET 1 OF 1	
B	6688 Remove L1L AND L2L	6/12/2024	DSW	FRACTIONAL	± 1/32						
A	Combined drawings	3/23/18	DSW	ANGULAR	± 1°						
NO	REVISION	DATE	BY								