


(Customer Connections)
Markings On Coils
For Reference Only.



480 Rated Voltage, 600 Max Voltage, Output							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL1PE01	350	414	420	26.4	155	275	SLK13
KDRULL2PE01	400	477	480	23.1	165	267	SLK13
KDRULL3PE01	450	515	600	19	170	338	SLK14
KDRULL4PE01	500	590	600	18.7	170	338	SLK14

575 Rated Voltage, 600 Max Voltage, Output							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL31PE01	400	382	420	26.5	155	420	SLK13
KDRULL35PE01	450	412	420	26.4	155	420	SLK13
KDRULL32PE01	500	472	480	23.7	165	480	SLK13

480 Rated Voltage, 600 Max Voltage, High Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL1H0E1	250	302	310	106	174	548	SLK13
KDRULL2HE01	300	361	365	86	175	786	SLK13
KDRULL3HE01	350	414	435	74	179	750	SLK13
KDRULL4HE01	400	477	480	65	205	730	SLK13

TCI (800) 824-8282 transcoil.com

TCI, LLC
Germantown, WI, USA
transcoil.com
800-824-8282

KDRUL Drive Reactor
KDRUL Motor Amps —
3PH, 50/60Hz, —V Rated, 600V Max, —A Max
40C Amb Max, 185C Rise, RoHS
Term Torque — lb-in

UL LISTED
cULus LISTED
330-CAN-UL-99-0000

DATE CODE: A1

- Note: 1. UL file number: cULus Listed File E116124.
2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
4. Material(s) Shall be RoHS Compliant
5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°				W132N10611 (Rev 1) Feb Germantown, WI 53012 © 2024 TCI, LLC KDRUL L Frame Enclosed Type I	
B	6688, KDRULL, 610A to 575A Max.	6/12/2024	DSW	DATE		3/22/2018	DSW	107614-6DG	
A	As Designed	3/22/2018	DSW	DATE			DSW		
NO	REVISION	DATE	BY	DATE			SCALE: 1/6	SHEET 1 OF 1	