



208/240 Rated Voltage, 600 Max Voltage, Low Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Size (Inches)
KDRJ23LE3R	150	396	420	25.5	140	401	SLK13	0.53
KDRJ24LE3R	200	528	534	21.8	140	442	SLK14	0.53

  

480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Size (Inches)
KDRJ2LE3R	350	414	450	44	136	465	SLK14	0.53
KDRJ1LE3R	400	477	520	37.5	136	470	SLK14	0.53

**TCI** (800) 824-6282 [trancoil.com](http://trancoil.com)

TCI, LLC  
Greenwood, WI, USA  
[trancoil.com](http://trancoil.com)  
800-824-6282

KDR J Frame  
KDR - Motor Amps -  
3PH, 50/60Hz, -V Rated, 600V Max, -A Max  
40C Amp Max, 150C Max, Part#  
Manual #30895 L140 KIT 40LX-

DATE CODE

- Notes:
- KDR Lug Kits sold separately. Contact TCI.
  - UL file number: cULus Listed File E116124.
  - KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
  - KDR IOM Manual Part Number 30895
  - NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
  - Material(s) Shall be RoHS Compliant
  - Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10				W132N10611 (Rev 1) Feb Greenwood, WI 53012 © 2024 TCI, LLC An Allied Motion Company KDR J Frame Enclosed Type 3R	
B	668S, J2L 500A to 450A Max	6/13/2024	DSW	FRACTIONAL ± 1/32		DRN BY DSW	DATE 4/25/2018	107621-7DG	
A	Combined Drawings	4/25/2018	DSW	ANGULAR ± 1°		SCALE 1/5	REVISED	ENCLOSURE	
NO	REVISION	DATE	BY					SHT 1 OF 1	