







TCI Part Number	Rated Amps (A)	Max Amps (A)	--uH+/-10%	Weight (LBS)	Available Lug Kit	Terminal Hole Size (Inches)
KDRJ4R	480	480	320	85	SLK14	0.56

- Notes:
1. UL file number: cULus Listed File E116124.
 2. V1K Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 3. V1K IOM Manual Part Number 31259
 4. Material(s) Shall be RoHS Compliant
 5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.
 6. Dimensions are in inches unless otherwise specified.



V1K SCHEMATIC



TOLERANCES (EXCEPT AS NOTED)		THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIENT INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIENT INC. AND ITS SUBSIDIARIES.		DESIGNED BY	DSW		W132N10611 Grant Drive Germantown, WI 53022 © 2024 Allient Inc.
DECIMAL	.XX ± .25 .XXX ± .10	DATE	8/13/18	SCALE	1/2.2		KDR V1K Output Inductor 480 Amps, 480V
FRACTIONAL	± 1/32	NO.	REVISION	DATE	BY	107832DG	SIZE C
ANGULAR	± 1°			DATE	BY		SHT. 1 OF 1