



480 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULF2H	60	77	77	408	26	226	SLK10

TCL (800) 824-8282 transcoil.com
 TCL, LLC Germantown, WI, USA. transcoil.com 800-824-8282
 KDRUL F Drive Reactor Motor Amps ---
 3PH, 50/60Hz, ---V Rated, 600V Max, ---A Max, RoHS
 40C Amb Max, 138C Rise Manual #30885
 UL LISTED CE
 3000 0000 00 0000
 DATE CODE A1 A2 B1 C1 C2

- Notes:
- UL file number: cULus Listed File E116124.
 - KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 - KDR IOM Manual Part Number 30895
 - NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 - Material(s) Shall be RoHS Compliant
 - Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

TCL, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCL AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCL.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/16 ANGULAR ± 1°				W132 N10611 Grant Drive Germantown, WI 53022 KDRUL F Frame, Ring Lug. Reactor Drawing DRN BY DSW DATE 1/15/19 107988-2 SCALE: 1/2 DRIVEN BY JSC SHEET 1 OF 1	
C	5018, Bend Terminals To Meet Clearance	1/3/2020	DSW						
B	4608, Design Updated	1/15/19	DSW						
NO	REVISION	DATE	BY						