

UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
3	5TH	240	60	3	10
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		55			


SYMBOL	TCI PART NUMBER
LR	KDRE21T
TR	KTR3B65HG
CAP1, 2, 3, 4	KCAP3A6A
Fu1, 2, 3	15752

PB-POWER INPUT BLOCK:
 WIRE RANGE-#18 TO #4 AWG.
 TIGHTENING TORQUE 20 IN-LB.

GROUND LUG:
 WIRE RANGE-1/0 TO #14 AWG.
 1/0 AWG thru 2 AWG 50 IN-LBS. MAX.
 4 AWG thru 6 AWG 45 IN-LBS. MAX.
 8 AWG 40 IN-LBS. MAX.
 10 AWG thru 14 AWG 35 IN-LBS. MAX.

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS.
 CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

TOLERANCES (EXCEPT AS NOTED)				 7878 N. 86th STREET MILWAUKEE, WI 53224
DECIMAL				
.XX ± .02 .XXX ± .01				
FRACTIONAL				H10BW00ST, HG7 STANDARD 10HP, 240/3/60, OPEN
± 1/32				
ANGULAR				DRN. BY DSW DATE 03/02/05 DWG. NO. 102506DG SCALE TO FIT APRVD. CHT.1 OF 1
± 1/2°				
NO	REVISION	DATE	BY	
B	2516, CAP WAS 16446	9/30/07	RJC	
A	MOVED POWER BLOCK	2/21/06	DSW	

SEE 25178 FOR SCHEMATIC