






Alternate Rain Hood Construction.

Unit Specifications					
kVar	Harmonic	Volt	HZ.	Phase	HP
15	5TH	600	60	3	75

TCI Part Number	Option	Weight	Schematic
HGL0075CW3S0000	Standard	265lbs	30807-1
HGL0075CW3C0000	Contactors	275lbs	30807

See IOM Manual For Wire Range And Tightening Torque.



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELETRICAL CODES.
 NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES
 Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREDJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
A	AS DESIGNED	10/4/17	DSW	DECIMAL .XX +/- .25 .XXX +/- .12 FRACTIONAL +/- 1/16 ANGULAR +/- 1°

	W132 N10611 GRANT DRIVE GERMANTOWN, WI 53022
	HGL0075CW3C0000, 600V, 75HP, 3 Phase HGL0075CW3S0000, 600V, 75HP, 3 Phase 60 Hz, Type 3R, Low C, Passive Harmonic Filter
DRN. BY DSW	DATE 10/4/17
SCALE 1/8	DWG. No. 107307DG
SHEET 1 OF 1	