


4 3 2 1







Alternate Rain Hood Construction.

Unit Specifications					
kVar	Harmonic	Volt	HZ.	Phase	HP
40	5TH	480	60	3	250

TCI Part Number	Option	Weight	Schematic
HGL0250AW3S0000	Standard	550lbs	30586-1S
HGL0250AW3C0000	Contactors	555lbs	30586-1C

See IOM Manual For Wire Range And Tightening Torque.



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREDJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
A	AS DESIGNED	6/1/17	DSW	DECIMAL .XX +/- .25 .XXX +/- .12 FRACTIONAL +/- 1/16 ANGULAR +/- 1°

**TCI**® W132 N10611 Grant Drive  
 Germantown, WI 53022  
 HGL0250AW3C0000, 480V, 250HP, 3 Phase  
 HGL0250AW3S0000, 480V, 250HP, 3 Phase  
 60 Hz, Type 3R, Low C, Passive Harmonic Filter

DRN. BY: DSW  
 SCALE: 1/8

DATE: 6/1/17  
 APRVD.

DWG. No.: 107036DG  
 SHEET 1 OF 1

4 3 2 1