


4 3 2 1







Alternate Rain Hood Construction.

Unit Specifications					
kVar	Harmonic	Volt	HZ.	Phase	HP
40	5TH	600	60	3	250

TCI Part Number	Option	Weight	Schematic
HGL0250CW3S0000	Standard	545lbs	30807-1
HGL0250CW3C0000	Contactors	550lbs	30807

See IOM Manual For Wire Range And Tightening Torque.



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELETRICAL CODES.

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREDJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
A	AS DESIGNED	10/5/17	DSW	DECIMAL .XX +/- .25 .XXX +/- .12
				FRACTIONAL +/- 1/16
				ANGULAR +/- 1 °

**TCI** W132 N10611 GRANT DRIVE GERMANTOWN, WI 53022

HGL0250CW3C0000, 600V, 250HP, 3 Phase  
HGL0250CW3S0000, 600V, 250HP, 3 Phase  
60 Hz, Type 3R, Low C, Passive Harmonic Filter

DRN. BY: DSW DATE: 10/5/17 DWG. No.: 107312DG  
SCALE: 1/8 APRVD.

SHEET 1 OF 1

4 3 2 1