




Alternate Rain Hood Construction.

Unit Specifications					
kVar	Harmonic	Volt	HZ.	Phase	HP
55	5TH	600	60	3	350


TCI Part Number	Option	Weight	Schematic
HGL0350CW3S0000	Standard	650lbs	30807-S
HGL0350CW3C0000	Contactor	665lbs	30807-C

See IOM Manual For Wire Range And Tightening Torque.

Customer Connection
L1 L2 L3
T1 T2 T3
Suggested Customer Enclosure Entry.



0.50 Dia Holes
9 Places.



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELETRICAL CODES.
NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREDJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
A	AS DESIGNED	10/9/17	DSW	DECIMAL .XX +/- .25 .XXX +/- .12 FRACTIONAL +/- 1/16 ANGULAR +/- 1°

TCI W132 N10611 GRANT DRIVE GERMANTOWN, WI 53022

HGL0350CW3C0000, 600V, 350HP, 3 Phase
HGL0350CW3S0000, 600V, 350HP, 3 Phase
60 Hz, Type 3R, Low C, Passive Harmonic Filter

DRN. BY: DSW DATE: 10/9/17 DWG. No.: 107314DG
SCALE: 1/8 APRVD. SHEET 1 OF 1