



HGL0800AW-----			
Components	1S000#	1C000#	1C*00#
Line Reactor (LR)	X	X	X
Trap Reactor (TR)	X	X	X
Capacitor (Cap)	X	X	X
Trap Fusing, FU1, FU2, FU3	X	X	X
Contactor (CNT)		X	X
Transformer (XFMR)	X	X	X
XFMR Fusing, FU4, FU5	X	X	X
PQConnect Board			X

*	Communication Options
1	PQconnect W/Modbus RTU over RS485
2	PQconnect W/EtherNET/IP

#	Mechanical Options
0	No Mechanical Option
T	T/S Option

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
G	6709 Options, Reactor Orientation	06/27/24	JRN
F	6266, KDRY3TT to KDRX3STT	5/10/2023	DSW
E	6024 Add PQ Option	8/26/22	JTL
D	5653, GE to ABB CNT CHG.	1/31/2022	DSW
C	5554 Updated Trap, Weights, DB	04/05/21	JRN
B	Add PQ Connect	3/12/19	DSW

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

W132N10611 Grant Drive
Germantown, WI 53022
© 2022 TCI, LLC

HarmonicGuard Low Capacitance
HGL, 800HP, 480/3/60, Type 1

DRN BY: DSW DATE: 10/13/17 SIZE: C
SCALE: 1/8 APRVD: 107276DG

ANGULAR ± 1°
SHT. 1 OF 1