




HGP Part Number	HorsePower (HP)	kVar	Harmonic	Voltage (V)	Hz.	Phase
HGP0005AW3----	5	1.2	5th	480	60	3

HGP Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0005AW3S0000	28697-2S	100
HGP0005AW3C0000	28697-2	101
HGP0005AW3C000H	28697-2H	105
HGP0005AW3S1000	29597-PQ3	103
HGP0005AW3C1000	29597-PQ2	104
HGP0005AW3C100H	29597-PQ2H	108

Note: For Torque Information See IOM Manual

Customer Connections.
L1, T1, L2, T2, L3, T3
Wire Range: 18 AWG to 4 AWG.

Ground Lug
Wire Range: 1/0 to 14 AWG.



Components	HGP0005AW3----					
	S0000	C0000	C000H	S1000	C1000	C100H
Line Reactor (LR)	x	x	x	x	x	x
Trap Reactor (TR)	x	x	x	x	x	x
Capacitor (Cap)	x	x	x	x	x	x
Trap Fusing, FU1, FU2, FU3	x	x	x	x	x	x
Contactor (CNT)		x	x		x	x
Transformer (XFMR)	x	x	x	x	x	x
XFMR Fusing, FU4, FU5	x	x	x	x	x	x
Heater			x			x
PQConnect Board				x	x	x

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.	DRN	6/11/18	DATE	BY	TOLERANCES (EXCEPT AS NOTED)	W132 N10611 Grant Drive Germantown, WI 53022 HarmonicGuard Passive HGP, 5HP, 480/3/60, Type 3R
	D	Add PQConnect	6/11/18		DECIMAL	
	NO	REVISION	DATE	BY	FRACTIONAL	
					ANGULAR	
					± 1°	DRN BY: DSW DATE: 1/23/14 SCALE: 1/8 APRVD: SIZE C 105587DG SHT 1 OF 1