




HGP Part Number	HorsePower (HP)	kVar	Harmonic	Voltage (V)	Hz.	Phase
HGP0010AW3----	10	3	5th	480	60	3

HGP Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0010AW3S0000	28697-2S	112
HGP0010AW3C0000	28697-2	113
HGP0010AW3C000H	28697-2H	117
HGP0010AW3S1000	29597-PQ3	115
HGP0010AW3C1000	29597-PQ2	116
HGP0010AW3C100H	29597-PQ2H	120

Note: For Torque Information See IOM Manual

Customer Connections.
L1, T1, L2, T2, L3, T3
Wire Range: 18 AWG to 4 AWG.

Ground Lug
Wire Range: 1/0 to 14 AWG.



Components	HGP0010AW3----					
	S0000	C0000	C000H	S1000	C1000	C100H
Line Reactor (LR)	x	x	x	x	x	x
Trap Reactor (TR)	x	x	x	x	x	x
Capacitor (Cap)	x	x	x	x	x	x
Trap Fusing, FU1, FU2, FU3	x	x	x	x	x	x
Contactor (CNT)		x	x		x	x
Transformer (XFMR)	x	x	x	x	x	x
XFMR Fusing, FU4, FU5	x	x	x	x	x	x
Heater			x			x
PQConnect Board				x	x	x

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.	DRN BY	DATE	BY	SCALE	APRVD	SIZE	TCI W132 N10611 Grant Drive Germantown, WI 53022 HarmonicGuard Passive HGP, 10HP, 480/3/60, Type 3R 105552DG SHT 1 OF 1
	B Add PQConnect	6/11/18		1/8		C	
	NO REVISION	DATE	BY	ANGULAR			
				± 1°			