

HGP Open Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0015CW0S0000	29474	51
HGP0015CW0C0000	29474-1	55
HGP0015CW0S1000	29474-PQ1	53
HGP0015 CW0C1000	29474-PQ	58




HGP Part Number	HorsePower (HP)	kVar	Harmonic	Voltage (V)	HZ.	Phase
HGP0015CW----	15	5	5th	600	60	3

HGP Enclosed Type 1 Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0015CW1S0000	29597-S	76
HGP0015CW1C0000	29474-1	80
HGP0015CW1S1000	29474-PQ1	78
HGP0015CW1C1000	29474-PQ	83

Note: For Torque Information See IOM Manual

Customer Connections.  
L1, T1, L2, T2, L3, T3  
Wire Range: 1 AWG to 22 AWG.

Ground Lug  
Wire Range: 1/0 to 14 AWG.



Note: Customer is responsible for proper cooling of filter components on open panels. Capacitors Maximum Ambient 50°C.

HGP0015CW----				
Components	0S0000/1S0000	0C0000/1C0000	0S1000/1S1000	0C1000/1C1000
Line Reactor (LR)	X	X	X	X
Trap Reactor (TR)	X	X	X	X
Capacitor (Cap)	X	X	X	X
Trap Fusing, FU1, FU2, FU3	X	X	X	X
Contactor (CNT)	X	X	X	X
Transformer (XFMR)	X	X	X	X
XFMR Fusing, FU4, FU5	X	X	X	X
PQConnect Board			X	X

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.	TOLERANCES (EXCEPT AS NOTED)		W132 N10611 Grant Drive Germantown, WI 53022 HarmonicGuard Passive HGP, 15HP, 600/3/60, Open and Type 1.	
	DECIMAL	.XX ±.25 .XXX ±.10		
	FRACTIONAL	± 1/16		
	ANGULAR	± 1°		
C	PQConnect Board Added.	8/23/18	DSW	DWN BY: DSW DATE: 4/03/17 SCALE: 1/8 DRAWN: DATE: 107048DG NO. REVISION DATE BY

D  
C  
B  
A

D  
C  
B  
A