


HGP Part Number	HorsePower (HP)	kVar	Harmonic	Voltage (V)	Hz.	Phase
HGP0200AW3----	200	60	5th	480	60	3




Note: For Torque Information See IOM Manual




Customer Connections.
L1, L2, L3, T1, T2, T3
Wire Range: Two, 350MCM to 2AWG.

Ground Lug
Wire Range: Two, 350MCM to 2AWG.

HGP Part Number	Schematic Drawing #	Approx Weight (LBS)
HGP0200AW3S0000	28697-4S	470
HGP0200AW3C0000	28697-4	475
HGP0200AW3C000H	28697-4H	480
HGP0200AW3S1000	29587-PQ1	473
HGP0200AW3C1000	29597-PQ	478
HGP0200AW3C100H	29597-PQH	482



PQConnect Board
Optional



HGP0200AW3----						
Components	S0000	C0000	C000H	S1000	C1000	C100H
Line Reactor (LR)	x	x	x	X	X	X
Trap Reactor (TR)	x	x	x	X	X	X
Capacitor (Cap)	x	x	x	X	X	X
Trap Fusing, FU1, FU2, FU3	x	x	x	X	X	X
Contactor (CNT)		x	x		X	X
Transformer (XFMR)	x	x	x	X	X	X
XFMR Fusing, FU4, FU5	x	x	x	X	X	X
FU6						X
Heater			x			X
PQConnect Board				X	X	X

Customer Is Responsible For Installation to Meet All National And Local Electrical Codes.

NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

TOLERANCES (EXCEPT AS NOTED)			
DECIMAL	.XX ± .25	.XXX ± .10	
FRACTIONAL	± 1/16		
ANGULAR	± 1°		

TCI W132 N10611 Grant Drive
Germantown, WI 53022

HarmonicGuard Passive
HGP, 200HP, 480/3/60, Type 3R

DRN BY DSW DATE: 1/16/14 105564DG
SCALE: 1/8 APRVD: SIZE C SHT. 1 OF 1

D

C

B

A

D

C

B

A

4

3

2

1

4

3

2

1