



480 Rated Voltage, 600 Max Voltage, High Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Size (Inches)
KDRG1HE01	150	180	185	181	126	359	SLK11	0.38

TCI (800) 824-8282 transcoil.com

TCL, LLC
 Germantown, WI, USA.
transcoil.com
 800-824-8282

KDRUL Drive Reactor
 KDR- Motor Amps ---
 SFL, 480V/600V, ---V Rated, 600V Max, -A Max
 40C Amps Max, 430C Max, Part 10
 Manual 430C LUG KIT 480V

UL LISTED
 336 0000 10 0000

DATE CODE

- Notes:
1. KDR Lug Kits sold separately. Contact TCI.
 2. For KDRUL version With Terminal Lugs Attached, See Sheet 4
 3. UL file number: cULus Listed File E116124.
 4. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 5. KDR IOM Manual Part Number 30895
 6. Material(s) Shall be RoHS Compliant
 7. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

TCL, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCL AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCL.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/16 ANGULAR ± 1°				W132 N10611 Grant Drive Germantown, WI 53022 KDR G Frame, Copper Bus, Enclosed Type 1, Reactor Drawing	
A	5013, Was on sheet 3	12/20/19	DSW	DRN BY	DATE	12/20/19	107610DG		
NO	REVISION	DATE	BY	SCALE:	1/6	DRYD	SHT 7 OF 8		