




Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Size (Inches)
KDRG1HE01	150	180	185	181	126	245 SLK10	0.28

480 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Ground Lug. See IOM Manual, Part# 30895 Table S2/0, Wire Size And Torque.

Suggested Customer Wire Entrance Bottom Of Enclosure. See Note: 6 (Non Removeable Panel)

Suggested Customer Entrance Either Side Of Enclosure. See Note: 6 (Non Removeable Panel)



- Notes:
1. KDR Lug Kits sold separately. Contact TCI.
 2. UL file number: cULus Listed File E116124.
 3. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 4. KDR IOM Manual Part Number 30895
 5. Material(s) Shall be RoHS Compliant
 6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10		W132N10611 (Rev 11/16) Germantown, WI 53022 © 2024 TCI, LLC	
B	6677, Update Termination to 32766	5/21/2024	DSW	FRACTIONAL ± 1/32	KDRG1HE01		
A	5013, Was 107610-3	12/20/19	DSW	ANGULAR ± 1°	Type 1, Enclose Reactor		
NO	REVISION	DATE	BY	SCALE: 1/5	DATE: 12/20/2019	107610-7DG	SHT 1 OF 1