


480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULS1L	700	840	840	26	170	872	SLK16



**TCL** (800) 824-8282 [transcoll.com](http://transcoll.com)

TCL, LLC  
 Germantown, WI, USA  
[transcoll.com](http://transcoll.com)  
 800-824-8282

KDRUL Drive Reactor  
 KDRUL— Motor Amps —  
 3PH, 50/60Hz, —V Rated, 600V Max, —A Max  
 40C Amb Max, 155C Rise, RoHS  
 Term Torque — 10-in

UL LISTED  
 2008 Edition, 1p, 2000

DATE CODE: A1, B1, C1

- Note:
1. UL file number: cULus Listed File E116124.
  2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
  3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
  4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
  5. Material(s) Shall be RoHS Compliant
  6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

TCL, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCL AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCL.				TOLERANCES (EXCEPT AS NOTED)		W132 N10611 Grant Drive Germantown, WI 53022	
				DECIMAL		KDRUL S Frame, Copper Bus Reactor Drawing	
				.XX ± .25 .XXX ± .10		DRN BY: DSW DATE: 3/2/18 107538DG	
				FRACTIONAL		SCALE: 1/3.2	
				± 1/16		REV: 00	
				ANGULAR		SHT 6 OF 10	
				± 1°			
A	Combine drawings	3/2/18	DSW				
NO	REVISION	DATE	BY				