

480 Rated Voltage, 600 Max Voltage, High Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULS2H	700	840	840	37.2	290	805	SLK16


TCL (800) 824-8282 transcoll.com

TCL, LLC
 Germantown, WI, USA.
transcoll.com
 800-824-8282

KDRUL Drive Reactor
 KDRUL— Motor Amps —
 3PH, 50/60Hz, —V Rated, 600V Max, —A Max
 40C Amb Max, 155C Rise, RoHS
 Term Torque— lb-in

UL LISTED
 2ND CONT. EQ. 2000

DATE CODE A1 B1 C1 A2 B2 C2



- Note:
1. UL file number: cULus Listed File E116124.
 2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
 4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 5. Material(s) Shall be RoHS Compliant
 6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

TOLERANCES (EXCEPT AS NOTED)			W132N10611 Grant Drive Germantown, WI 53022 © 2021 TCL, LLC	
DECIMAL			.XX ± .25	
FRACTIONAL			.XXX ± .10	
ANGULAR			± 1°	
B	5548 Updated Lug Kit	03/30/21	JRN	REVISION
A	Combined Drawings	03/02/18	DSW	DATE
NO				BY
SCALE: 1/3.2		DATE: 03/02/18		DRN: DSW
APRVD:		105738DG		SIZE: C
SHT 6 OF 8				