




480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL3L	600	720	750	26	115	510	SLK15

575 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL43L	700	672	675	34	130	590	SLK15



(Customer Connections) Markings On Pressure Terminals For Reference Only.




TCL (800) 824-8282 transcoil.com

TCL, LLC
Germanstown, WI, USA.
transcoil.com
800-824-8282

KDRUL Drive Reactor
KDRUL Motor Amps —
3PH, 50/60Hz, —V Rated, 600V Max, —A Max
40C Amb Max, 150C Rise, RoHS
Term Torque — 1/2 in

UL LISTED CE
200 0207, 10, 1000

DATE CODE A1 A2 B1 B2 C1 C2



- Note: 1. UL file number: cULus Listed File E116124.
- 2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
- 3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
- 4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
- 5. Material(s) Shall be RoHS Compliant
- 6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

REV	DATE	BY	DESCRIPTION
B	5/10/2021	DSW	Terminal Updated
NO			REVISION

TOLERANCES (EXCEPT AS NOTED)		DATE	
DECIMAL	.XX ± .25 .XXX ± .10	DATE	3/23/2018
FRACTIONAL	± 1/16	DATE	10/7537DG
ANGULAR	± 1°	SCALE	1/3.2

TCL W132N10611 Grant Drive
Germanstown, WI 53022
© 2021 TCL, LLC

An Official Motion Company
KDRUL L Frame, Copper Bus
Reactor Drawing

DWG BY: DSW DATE: 3/23/2018 107537DG
SCALE: 1/3.2 REVISED: DATE: FILE: SHEET 8 OF 10