




| HP | CATALOG NO | RATED<br>_AMP(S) | MAX<br>_AMP(S) | APPROX WT-LBS |
|----|------------|------------------|----------------|---------------|
| 75 | KDRG43TT   | 57.98            | 77             | 60            |



TERMINAL BLOCK  
TORQUE(LB-IN)=CUSTOMER WIRE

- 35 = 1 AWG THRU 4 AWG
- 30 = 6 AWG THRU 14 AWG
- 25 = 16 AWG THRU 20 AWG
- 20 = 22 AWG

NOTE: A1, AT A2, B1, BT, B2, C1, CT C2,  
TERMINAL BLOCK AND COIL  
FOR REFERENCE ONLY.



|   |          |            |    |                                  |  |   |  |
|---|----------|------------|----|----------------------------------|--|---|--|
| <p>TCL, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCL AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCL.</p> |          |            |    | TOLERANCES<br>(EXCEPT AS NOTED): |  | W132 N10611 Grant Drive<br>Germantown, WI 53022                     |  |
|   |          |            |    | DECIMAL                          |  | .XX ± .03   |  |
|   |          | FRACTIONAL |    | ± 1/32                           |  | 75HP, 600V, HGP REACTOR   |  |
|   |          | ANGULAR    |    | ± 1/2°                           |  | DRN BY: DSW DATE: 5/19/14 DWG NO: 105668DG<br>SCALE: TO FIT SIZE: C |  |
| NO  | REVISION | DATE       | BY | SHT. 1 OF 1                      |  |   |  |