



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

VOLTS	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	RING TERMINAL HOLE SIZE.
690V	20	KLR25DRL2V	25	19	72	.25
3% Z						

NO	REVISION	DATE	BY	TOLERANCES EXCEPT AS NOTED	DECIMAL	FRACTIONAL	ANGULAR
				.XX ± .03		.XXX ± .010	± 1/16
				± 1/2°			

TCI 7878 N. 86th STREET
MILWAUKEE, WI 53224

**KLR SERIES 3 PH REACTOR
690V (FRAME C) ENCLOSED**

DRN BY: DSW DATE: 03/13/07 DWG. NO.: KLR25DRL2VDG
 SCALE: TO FIT APPR: SHT. 1 OF 1