



P/N	VOLTAGE	KVAR	EST. WEIGHT
KPCUL01.6C60	600	1.6	4.5
KPCUL003C60	600	3	4.5
KPCUL003.9A63	480	3.9	4.5

WIRE SIZE VS. TORQUE	
TORQUE (lb-in)	WIRE SIZE (AWG)
35	1 THRU 4
30	6 THRU 14
25	16 THRU 20
20	22

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THERE IN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY

Material(s) Shall be RoHS Compliant

TCI W132 N10611 Grant Drive
Germantown, WI 53022

KPCUL SMALL 6 CAP PANEL ASSEMBLY

DRN. BY JSM	DATE: 7/13/17	107159
SCALE: 1:2	APRVD:	

SIZE B SHT. 1 OF 1