


Tightening Torque 3 ± 0.15 Nm



Technical data and measuring conditions.

| | |
|---------------------------------|--|
| Rated Voltage V_R | 760/440 V AC, 50/60Hz. |
| Rated Current I_R | Referred to 40 °C ambient temperature |
| Test Voltage V_{test} | 3270 V DC, 2 s (line/line) 3000 V DC, 2 s (line/case) |
| Overload Capability (thermal) | $1.5 \cdot I_R$ for 3 min per hour or $2.5 \cdot I_R$ for 30 s per hour |
| Leakage Current I_{leak} | At 690 V AC, 50 Hz. |
| Climatic Category (IEC 60068-1) | 25/100/21 (-25 °C/+100 °C/21 days damp heat test) |
| Approval Standards | EN 133200, UL 1283, CSA C22.2 No. 8 |
| Approval Markings | UR, cUR |

| V_R AC V | I_R A | Terminal cross section mm ² | I_{leak} mA | $R_{typ.}$ m ohm | Approx. Weight kg. / lbs. |
|------------------|------------|--|------------------|---------------------|---------------------------------|
| 760/440 | 25 | 10 | < 7 | 8.0 | 4 / 8.8 |

| | | | | | |
|----|------------------|---------|---------------------------------|-----------------------|--|
| | | | TOLERANCES (EXCEPT AS NOTED) | | W132 N10611 Grant Drive Germantown, WI 53022 |
| | | | DECIMAL | .XX ±.02 .XXX ±.01 | |
| B | EDO 3959 ADDED | 4/12/17 | JRN | FRACTIONAL | KRF FILTER KRF0025VTB, 600-690V, 25A |
| A | UPDATE APPROVALS | 6/13/11 | DSW | ± 1/32 | |
| NO | REVISION | DATE | BY | ANGULAR | DRN BY DSW DATE 1/07/2010 DWG. NO. KRF0025VTB SCALE TO FIT APRVD. SHT.1 OF1 |