


CATALOG NO	__mH $\begin{matrix} +8\% \\ -2\% \end{matrix}$	__AMPS(A)	APPROX WT-LBS
KTR2L55HG	7.94	6.7	12

TCI TRANS-COIL, INC MILWAUKEE WI WWW.transcoil.com 800-824-8282 <small>DATE CODE</small>	Performance and Protection for Drives. KTR Tuning Reactor CATALOG# _____ 3PH, 50Hz, 600V Max, --- Amps 40C Amb Max, 115C Rise		

BLOCK WIRE RANGE FOR REACTOR AND TIGHTENING TORQUE. #18-#4 AWG 20 LB-IN



NOTE: A1, A2, B1, B2, C1, C2, MARKINGS TERMINAL BLOCK FOR REFERENCE ONLY.

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.				TOLERANCES (EXCEPT AS NOTED)	W132 N10611 Grant Drive Germantown, WI 53022	
				DECIMAL		
	C	3411 VOLTAGE UPDATE	9/3/2015	BWM	.XX ± .02	KTR2L55HG 6.7 AMPS, 400V, 50Hz.
	B	3290 M50 TO M6	4/29/15	DSW	.XXX ± .01	
	A	3257 UPDATE VOLTS	12/22/2014	BMZ	FRACTIONAL ± 1/32	DRN. BY DSW DATE 3/18/11 DWG. NO. 104647DG
NO	REVISION	DATE	BY	ANGULAR ± 1/2°	SCALE TO FIT SIZE B SHT.1 OF 1	