


CATALOG NO	__mH $\begin{matrix} +8\% \\ -2\% \end{matrix}$	__AMPS(A)	APPROX WT-LBS
KTR3L55HG	6.62	8	14

<b>TCI</b> TRANS-COIL, INC MILWAUKEE WI WWW.transcoil.com 800-824-8282	<b>Performance and Protection for Drives.</b> KTR Tuning Reactor CATALOG# _____ 3PH, 50Hz, 600V Max, --- Amps 40C Amb Max, 115C Rise		

BLOCK WIRE RANGE FOR REACTOR AND TIGHTENING TORQUE.	#18-#4 AWG 20 LB-IN
---	------------------------



NOTE: A1, A2, B1, B2, C1, C2, MARKINGS TERMINAL BLOCK FOR REFERENCE ONLY.

				TOLERANCES (EXCEPT AS NOTED)	7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .03	KTR3L55HG 8 AMPS, 400V, 50Hz.
				.XXX ± .01	
				FRACTIONAL ± 1/32	DRN. BY DSW
				ANGULAR ± 1/2°	DATE 3/18/11
NO	REVISION	DATE	BY		APRVD. B
					DWG. NO. 104648DG
					SCALE TO FIT
					SHT.1 OF1