


CATALOG NO	--mH $+8\%$ -2%	--AMPS(A)	APPROX WT-LBS
KTR4L55HG	5.36	10.70	15

TCI TRANS-COIL, INC MILWAUKEE WI WWW.transcoil.com 800-824-8282 <small>DATE CODE</small>	<i>Performance and Protection for Drives.</i> KTR Tuning Reactor CATALOG# _____ 3PH, 50Hz, 600V Max, --- Amps 40C Amb Max, 115C Rise		

BLOCK WIRE RANGE FOR REACTOR AND TIGHTENING TORQUE.	#18-#4 AWG 20 LB-IN
---	------------------------



NOTE: A1, A2, B1, B2, C1, C2, MARKINGS TERMINAL BLOCK FOR REFERENCE ONLY.

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY
----	----------	------	----

	W132 N10611 Grant Drive Germantown, WI 53022		
	KTR4L55HG 10.7 AMPS, 400V, 50Hz.		
	DRN. BY DSW SCALE TO FIT	DATE 3/18/11 SIZE B	DVG. NO. 104649DG SHT.1 OF 1
	TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .02 .XXX ± .01 FRACTIONAL ± 1/32 ANGULAR ± 1/2°		