



Notes:

- 1.) Refer to schematic #28282-1 on units with network gateways.
- 2.) 120Vac Input Power for the Display Interface PCB can be tapped off the Control Transformer 120Vac Output or provided externally. For external wiring, follow all NEC guidelines.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

T	CT consistency	10/27/21	JSG	TOLERANCES (EXCEPT AS NOTED)
S	Interface PCB 120V input	6/10/21	MJS	DECIMAL
R	ctl xfr/delta cap variants	4/27/21	MJS	.XX ± .03
Q	input option note update	6/10/20	MJS	.XXX ± .010
P	4273 14 Ga to CPT	2/5/18	MJS	FRACTIONAL ± 1/32
N	50/100A REDESIGN	9/12/17	MJS	ANGULAR ± 1°
NO	REVISION	DATE	BY	

TCL W132 N10611 Grant Drive
Germantown, WI 53022
© TCL, 2021
An Allied Motion Company

Schematic, 50-100A Active Filter, Bus Applied

DRN. BY	RHW	DATE	2/17/11	DWG. NO.	26463-04
SCALE	n/a	SIZE	A		SHT.1 OF 1