



Notes:

- 1) Refer to schematic #28283-1 on units with network gateways.
- 2) OT1 is located in the exhaust area of the inductor tunnel.
- 3) 120Vac Input Power for the Display Interface PCB can be tapped off the Control Transformer 120Vac Output secondary fuse or provided externally. For external wiring, follow all NEC guidelines.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
D	5762 CT consistency	10/28/21	JSG
C	added 120V pwr note	6/22/21	MJS
B	Rmvd N1 Door fans	2/16/21	MJS
A	Add Wire Colors to VFC	7/9/19	JHM
O	preliminary release	6/6/18	MJS

TOLERANCES (EXCEPT AS NOTED)		DRN. BY		DATE		DWG. NO.	
DECIMAL		MJS		6/6/18		31020	
FRACTIONAL		SCALE		SIZE		SHT.1 OF 1	
ANGULAR		n/a		A			

TCI An Allied Motion Company
 W132 N10611 Grant Drive
 Germantown, WI 53022
 © TCI, 2021

Schematic, 300/350A
 Active Filter